

---

**From:** [REDACTED]  
**To:** [REDACTED]  
**CC:** [REDACTED]  
**Sent:** 7/14/2021 9:08:41 AM  
**Subject:** RE: Rock Creek Dam

Hey [REDACTED]

I spoke with [REDACTED] They said the jumper that was cut is to the lighting arrestor. Distribution cut it

---

**From:** [REDACTED]  
**Sent:** Tuesday, July 13, 2021 3:18 PM  
**To:** [REDACTED]  
**Subject:** FW: Rock Creek Dam

I think this is Cresta Dam? [REDACTED] Thought it was Rock Creek Dam

[REDACTED]  
Power Generation Supervisor  
DeSabra Hydro – Electrical and Mechanical



---

**From:** [REDACTED]  
**Sent:** Monday, July 12, 2021 5:42 PM  
**To:** [REDACTED]  
**Subject:** Rock Creek Dam

[REDACTED]  
I was out trying to help Project Management scope the remaining UG , was trying to get the bank size and voltage and saw a jumper cut. Is there anyone that can validate loads for the facility? Since it's not metered there is no data.

Let me know if the jumper needs to be fixed and I can check with M& C

Thanks

[REDACTED]  
Supervisor- Construction Management  
Distribution Electric